



**MINIMUM STARTING TEMPERATURE -20°F OR -30° C**  
**MAXIMUM BALLAST TO LAMP DISTANCE: 10 FEET**  
**INSULATE UNUSED INPUT LEAD FOR 300 VOLTS**  
**INSULATE LAMP LEAD CRIMP FOR 1000 VOLTS**  
**INSTALL IN ACCORDANCE WITH NATIONAL ELECTRICAL CODE**