



00415H

MINIMUM STARTING TEMPERATURE -20°F OR -30° C  
MAXIMUM BALLAST TO LAMP DISTANCE: 10 FEET  
INSULATE UNUSED INPUT LEAD FOR 300 VOLTS  
INSULATE LAMP LEAD CRIMP FOR 1000 VOLTS  
INSTALL IN ACCORDANCE WITH NATIONAL ELECTRICAL CODE